

SEPTEMBER 2017

VOL. 17-8

PRATT'S

ENERGY LAW

REPORT



EDITOR'S NOTE: WHAT'S A LESSEE TO DO?

Victoria Prussen Spears

UNDER SCRUTINY: PA SUPERIOR COURT SPLITS FROM OWN PRECEDENT AND ALLOWS UNILATERAL OIL & GAS LEASE SEVERANCE IN MONTGOMERY

Jeremy A. Mercer

FINANCIAL HEDGES FOR U.S. GAS-FIRED POWER GENERATION FACILITIES

Daniel N. Budofsky, Michael T. Reese, Michael S. Hindus, and Olivia Matsushita

UPDATE ON U.S. FEDERAL TAX REFORM PROPOSALS AND THEIR EFFECT ON THE RENEWABLE ENERGY INDUSTRY

Gerald M. Feige

AT A CROSSROAD, FERC CONFERENCE ADDRESSES STATE ACTIONS IN THE CONTEXT OF FEDERAL WHOLESALE MARKET INTEGRITY AND POTENTIAL PATHS FORWARD

Gregory K. Lawrence, Thomas O. Lemon, and Kenneth M. Minesinger

NERC ISSUES RECOMMENDATIONS ON INVERTER-RELATED SOLAR OUTAGES

J. Daniel Skees and Mark C. Williams

Pratt's Energy Law Report

VOLUME 17

NUMBER 8

SEPTEMBER 2017

Editor's Note: What's a Lessee to Do?

Victoria Prussen Spears

279

Under Scrutiny: PA Superior Court Splits from Own Precedent and Allows Unilateral Oil & Gas Lease Severance in *Montgomery*

Jeremy A. Mercer

281

Financial Hedges for U.S. Gas-Fired Power Generation Facilities

Daniel N. Budofsky, Michael T. Reese, Michael S. Hindus, and Olivia Matsushita

296

Update on U.S. Federal Tax Reform Proposals and Their Effect on the Renewable Energy Industry

Gerald M. Feige

302

At a Crossroad, FERC Conference Addresses State Actions in the Context of Federal Wholesale Market Integrity and Potential Paths Forward

Gregory K. Lawrence, Thomas O. Lemon, and Kenneth M. Minesinger

306

NERC Issues Recommendations on Inverter-Related Solar Outages

J. Daniel Skees and Mark C. Williams

312

QUESTIONS ABOUT THIS PUBLICATION?

For questions about the **Editorial Content** appearing in these volumes or reprint permission, please email:

Jacqueline M. Morris at (908) 673-1528
Email: jacqueline.m.morris@lexisnexis.com
Outside the United States and Canada, please call (973) 820-2000

For assistance with replacement pages, shipments, billing or other customer service matters, please call:

Customer Services Department at (800) 833-9844
Outside the United States and Canada, please call (518) 487-3385
Fax Number (800) 828-8341
Customer Service Website <http://www.lexisnexis.com/custserv/>

For information on other Matthew Bender publications, please call

Your account manager or (800) 223-1940
Outside the United States and Canada, please call (937) 247-0293

ISBN: 978-1-6328-0836-3 (print)
ISBN: 978-1-6328-0837-0 (ebook)
ISSN: 2374-3395 (print)
ISSN: 2374-3409 (online)

Cite this publication as:

[author name], [*article title*], [vol. no.] PRATT’S ENERGY LAW REPORT [page number]
(LexisNexis A.S. Pratt);

Ian Coles, *Rare Earth Elements: Deep Sea Mining and the Law of the Sea*, 14 PRATT’S ENERGY
LAW REPORT 4 (LexisNexis A.S. Pratt)

This publication is sold with the understanding that the publisher is not engaged in rendering legal, accounting, or other professional services. If legal advice or other expert assistance is required, the services of a competent professional should be sought.

LexisNexis and the Knowledge Burst logo are registered trademarks of Reed Elsevier Properties Inc., used under license. A.S. Pratt is a registered trademark of Reed Elsevier Properties SA, used under license.

Copyright © 2017 Reed Elsevier Properties SA, used under license by Matthew Bender & Company, Inc. All Rights Reserved.

No copyright is claimed by LexisNexis, Matthew Bender & Company, Inc., or Reed Elsevier Properties SA, in the text of statutes, regulations, and excerpts from court opinions quoted within this work. Permission to copy material may be licensed for a fee from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, Mass. 01923, telephone (978) 750-8400.

An A.S. Pratt® Publication

Editorial Office
230 Park Ave., 7th Floor, New York, NY 10169 (800) 543-6862
www.lexisnexis.com

MATTHEW  BENDER

Editor-in-Chief, Editor & Board of Editors

EDITOR-IN-CHIEF

STEVEN A. MEYEROWITZ

President, Meyerowitz Communications Inc.

EDITOR

VICTORIA PRUSSEN SPEARS

Senior Vice President, Meyerowitz Communications Inc.

BOARD OF EDITORS

SAMUEL B. BOXERMAN

Partner, Sidley Austin LLP

ANDREW CALDER

Partner, Kirkland & Ellis LLP

M. SETH GINTHER

Partner, Hirschler Fleischer, P.C.

R. TODD JOHNSON

Partner, Jones Day

BARCLAY NICHOLSON

Partner, Norton Rose Fulbright

BRADLEY A. WALKER

Counsel, Buchanan Ingersoll & Rooney PC

ELAINE M. WALSH

Partner, Baker Botts L.L.P.

SEAN T. WHEELER

Partner, Latham & Watkins LLP

WANDA B. WHIGHAM

Senior Counsel, Holland & Knight LLP

Hydraulic Fracturing Developments

ERIC ROTHENBERG

Partner, O'Melveny & Myers LLP

Pratt's Energy Law Report is published 10 times a year by Matthew Bender & Company, Inc. Periodicals Postage Paid at Washington, D.C., and at additional mailing offices. Copyright 2017 Reed Elsevier Properties SA, used under license by Matthew Bender & Company, Inc. No part of this journal may be reproduced in any form—by microfilm, xerography, or otherwise—or incorporated into any information retrieval system without the written permission of the copyright owner. For customer support, please contact LexisNexis Matthew Bender, 1275 Broadway, Albany, NY 12204 or e-mail Customer.Support@lexisnexis.com. Direct any editorial inquires and send any material for publication to Steven A. Meyerowitz, Editor-in-Chief, Meyerowitz Communications Inc., 26910 Grand Central Parkway Suite 18R, Floral Park, New York 11005, smeyerowitz@meyerowitzcommunications.com, 718.224.2258. Material for publication is welcomed—articles, decisions, or other items of interest to lawyers and law firms, in-house energy counsel, government lawyers, senior business executives, and anyone interested in energy-related environmental preservation, the laws governing cutting-edge alternative energy technologies, and legal developments affecting traditional and new energy providers. This publication is designed to be accurate and authoritative, but neither the publisher nor the authors are rendering legal, accounting, or other professional services in this publication. If legal or other expert advice is desired, retain the services of an appropriate professional. The articles and columns reflect only the present considerations and views of the authors and do not necessarily reflect those of the firms or organizations with which they are affiliated, any of the former or present clients of the authors or their firms or organizations, or the editors or publisher.

POSTMASTER: Send address changes to Pratt's Energy Law Report, LexisNexis Matthew Bender, 121 Chanlon Road, North Building, New Providence, NJ 07974.

NERC Issues Recommendations on Inverter-Related Solar Outages

*By J. Daniel Skees and Mark C. Williams**

The authors of this article discuss a recent North American Electric Reliability Corporation report on the loss of 1,200 MW of solar generation in southern California during a system disturbance that unexpectedly caused inverters at solar generation facilities to trip or momentarily cease to operate. The report provides solar plant owners and engineers with recommendations to prevent future occurrences.

Inverter disconnect events increasingly pose a reliability risk with the growth of solar generation. On June 8, the North American Electric Reliability Corporation (“NERC”) released its report¹ on the loss of 1,200 MW of solar generation in southern California during a system disturbance that unexpectedly caused inverters at solar generation facilities to trip or momentarily cease to operate. The report provides solar plant owners and engineers with recommendations to prevent future occurrences. According to NERC, inverter disconnect events pose an increasing reliability risk given the expansion of solar generation.

Growing solar penetration has made the response of solar generators to system disturbances more critical. If NERC and utility-scale solar generators adopt the report’s recommendations, the likelihood of both recurrences and government-imposed regulations will be reduced. The Federal Energy Regulatory Commission’s (“FERC’s”) recent orders requiring renewable generation to promote frequency response² reactive power³ and ride-through capability⁴ indicate a willingness to impose regulatory requirements on renewable generation where FERC sees it as necessary to preserve system reliability. Separate and apart from NERC action and any voluntary industry response, the report may lead FERC to consider such action.

* J. Daniel Skees is a partner at Morgan, Lewis & Bockius LLP, representing electric utilities before the Federal Energy Regulatory Commission and other agencies on rate, regulatory, and transaction matters. Mark C. Williams is a partner at the firm representing clients in the electric power and natural gas industries. The authors may be reached at daniel.skees@morganlewis.com and mark.williams@morganlewis.com, respectively.

¹ <http://www.nerc.com/news/Pages/Solar-Loss-Disturbance-Report-Uncovers-Gap-in-Frequency-Measurement-Errors.aspx>.

² Docket No. RM16-6.

³ Order No. 827.

⁴ Order No. 828.

OVERVIEW AND CAUSES

On August 16, 2016, the Blue Cut fire ignited in southern California and spread toward an important transmission corridor containing four high-voltage lines. Faults on the four lines resulted in the loss of nearly 1,200 MW of solar generation.

NERC's subsequent investigation identified three contributors to the power loss.

- 1) The primary contributor was an incorrect perception by some inverters that system frequency fell below 57 Hz. At voltages below 57 Hz or above 63 Hz, an inverter automatically trips, ceasing to input current and remaining offline for five or more minutes, thus terminating the flow of power through that inverter and affecting related power flows. The affected inverters remained offline for seven minutes. While the drop in frequency during the faults was slight and never reached 57 Hz, the faults distorted voltage waveform momentarily, which caused the inverters to perceive a frequency below 57 Hz.
- 2) The secondary contributor was momentary cessation of power flow through some inverters due to system voltages operating outside their normal range. Outside the normal voltage ratio range of 0.9 to 1.1 per unit, inverters suspend current injection until the voltage normalizes. Many inverters momentarily ceased injecting current. Restoration began immediately, but it took two minutes to fully restore the lost power.
- 3) The tertiary contributor was that DC overcurrent protection tripped some inverters after they started the momentary cessation operation. The cause of this trip remains unknown and under investigation.

The investigation also revealed that similar inverter disconnects had occurred during other disturbances in the recent past.

INVESTIGATION FINDINGS

NERC's investigation found that inverters that trip instantaneously based on near instantaneous frequency measurements may trip erroneously when faults distort waveform. While the PRC-024-2 Reliability Standard specifies a no-trip range for voltage and frequencies, solar generation owners and inverter manufacturers do not generally consider the standard to prohibit momentary cessations. Further, owners and manufacturers generally believe that anything outside the no-trip range is in a must-trip range.

The investigation also found that most installed inverters will momentarily cease providing current immediately when voltages go outside their normal

operating range. These inverters require major modifications or replacement to stop this inverter response, but some inverter manufacturers are no longer operating, suggesting a recognition that such modification or replacement might not be possible.

NERC's investigation then found that inverter manufacturers are using the Institute of Electrical and Electronics Engineers ("IEEE") 1547-2003 standard, which many generator owners believe they must meet—even though the IEEE standard conflicts with PRC-024-2.

The investigators concluded that this type of disturbance presents a previously unknown reliability risk, which is expanding as the use of solar generation increases.

NERC'S RECOMMENDATIONS

NERC's investigation resulted in several recommendations to mitigate or prevent future occurrences.

- 1) NERC should review PRC-024-2 to determine whether to revise the standard to (a) indicate that momentary cessation of inverter-connected resources is not allowed within the "no trip" area of the voltage curves, (b) clarify that outside the frequency curves is a "may trip" area, and (c) impose a required delay for the lowest levels of frequency. A revision to this standard could affect numerous utility-scale solar generating facilities.
- 2) NERC should alert registered Generator Owners and Generator Operators as to the risk and the recommended changes to inverter settings, especially given the proliferation of solar development. This alert would be directed only to those generating entities that are subject to NERC reliability regulation; it remains to be seen whether utilities or regulators will seek to alert or impose related requirements on smaller, non-NERC-regulated solar facilities.
- 3) NERC should perform more detailed studies with affected entities to determine (a) the extent of the risk posed by momentary cessation or tripping and (b) whether momentary cessation should be allowed in areas with higher penetrations of inverter-connected resources for voltages that are outside of their operating range.
- 4) NERC should work with FERC, IEEE, Underwriter Laboratories ("UL"), the National Fire Protection Association, and states to de-conflict inverter design and operation standards. NERC should also investigate whether it should develop an inverter standard for generators connected to transmission systems.

- 5) Manufacturers and operators should configure those inverters that momentarily cease operating when they sense conditions outside their operating range to restore to normal levels within five seconds. Design changes to inverter configuration would likely have to be approved by industry and insurance standard-setting entities, such as UL, before becoming effective. Manufacturing evolution of this nature is not unknown in the renewable power sector; for example, when wind generation technology was viewed as being subject to voltage irregularity, manufacturers developed new-generation turbines that possess low-voltage ride-through capability.

“Knowing that [the fault causing inverters to erroneously trip or momentarily cease] was not an isolated incident and considering the rapid increase in solar installations . . . these types of inverter disconnect events could be a potential reliability risk that needs to be analyzed and mitigated,” NERC concluded.

